

## 91 年 1 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
01/01	21.6	7.08	3.20	15.9	--
01/02	21.8	7.09	3.20	11.9	--
01/03	22.2	7.14	7.00	15.9	6.3
01/04	23.8	7.07	3.00	23.2	2.1
01/05	23.8	7.08	2.60	30.2	--
01/06	23.6	7.06	3.60	37.1	--
01/07	23.9	7.11	6.00	21.7	4.2
01/08	23.1	7.05	6.30	52.1	14.5
01/09	23.9	6.99	3.60	45.3	20.4
01/10	23.3	7.02	6.30	49.0	19.4
01/11	24.5	6.96	4.80	28.0	11.0
01/12	24.7	7.01	6.30	49.1	--
01/13	24.8	7.04	6.00	26.4	--
01/14	25.9	6.92	2.71	26.4	11.9
01/15	26.5	7.13	1.90	49.1	9.8
01/16	26.3	7.05	2.75	46.5	12.4
01/17	26.4	7.08	2.85	19.5	8.3
01/18	26.1	7.02	6.50	31.2	7.4
01/19	25.5	7.09	2.00	34.3	--
01/20	23.9	7.07	1.65	30.5	--
01/21	21.8	7.03	2.46	49.5	20.3
01/22	24.1	6.98	1.75	32.8	14.1
01/23	23.9	7.00	3.65	44.9	13.1
01/24	24.2	7.03	3.10	47.6	11.5
01/25	24.7	7.04	5.80	50.0	9.3
01/26	24.8	7.10	4.00	51.6	--
01/27	24.1	7.08	4.90	43.6	--
01/28	24.0	7.09	6.80	23.8	--
01/29	24.0	7.02	4.90	31.5	--
01/30	24.2	7.02	7.00	40.0	--
01/31	24.0	7.02	5.30	44.0	--
平均	24.2	7.05	4.26	35.6	11.53