

## 91年5月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
05/01	25.1	6.7	2.9	49.5	--
05/02	26.1	7.0	4.5	47.4	10.2
05/03	28.5	7.0	6.4	46.1	9.8
05/04	27.5	7.9	6.3	42.2	--
05/05	27.4	7.9	6.4	43.7	--
05/06	28.2	7.0	6.6	50.8	7.2
05/07	28.8	7.1	5.6	45.5	--
05/08	28.8	7.1	6.6	51.8	11.3
05/09	28.6	7.2	6.6	46.3	14.2
05/10	28.6	7.3	6.6	45.7	5.9
05/11	27.0	7.3	6.6	30.0	--
05/12	27.2	7.1	3.4	36.4	--
05/13	29.0	7.1	5.5	51.2	8.5
05/14	29.1	7.0	6.8	46.4	--
05/15	29.0	7.1	5.1	43.2	14.2
05/16	28.6	6.9	5.3	48.4	5.2
05/17	26.5	7.0	6.1	42.9	12.1
05/18	28.2	7.1	5.3	51.4	--
05/19	28.1	7.0	5.8	51.4	--
05/20	28.4	7.0	6.6	26.9	9.7
05/21	28.4	7.0	6.8	39.5	--
05/22	27.9	7.1	6.0	44.4	7.2
05/23	25.5	7.4	6.5	52.4	8.2
05/24	28.4	7.0	6.0	27.8	6.1
05/25	28.8	7.3	5.4	41.9	--
05/26	27.2	6.5	6.8	39.7	--
05/27	28.5	7.1	4.7	45.2	--
05/28	24.5	7.1	3.7	27.4	--
05/29	28.1	7.1	3.4	21.0	--
05/30	27.3	7.0	4.8	19.0	--
05/31	25.8	6.8	4.9	44.1	--
平均	27.7	7.10	5.6	41.9	9.3