

91 年 11 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/01	27.2	7.0	1.7	49.6	--
11/02	--	--	4.1	49.6	--
11/03	--	--	3.8	44.8	--
11/04	26.2	6.8	6.8	47.2	8.8
11/05	26.7	7.0	6.4	51.2	--
11/06	26.7	6.9	6.2	49.3	10.1
11/07	26.0	7.1	6.4	24.8	--
11/08	27.6	7.1	5.5	18.4	--
11/09	26.8	7.0	6.0	16.8	--
11/10	--	--	4.0	28.8	--
11/11	27.5	6.9	5.3	25.6	--
11/12	27.4	7.0	6.8	28.2	--
11/13	26.4	7.0	6.6	39.8	5.2
11/14	26.6	7.0	6.8	50.0	8.7
11/15	27.0	7.0	6.8	52.8	--
11/16	--	--	6.0	27.9	--
11/17	--	--	6.6	26.2	--
11/18	26.4	7.0	6.7	36.9	3.2
11/19	27.4	7.0	5.2	41.3	--
11/20	27.0	7.1	6.4	34.9	2.1
11/21	27.0	7.0	6.8	52.4	9.7
11/22	27.3	7.0	6.6	31.7	4.2
11/23	27.3	7.0	5.2	32.5	--
11/24	--	--	6.4	31.0	--
11/25	25.9	7.0	6.6	38.6	--
11/26	25.2	7.0	6.5	31.1	--
11/27	26.3	7.0	6.8	38.8	--
11/28	26.9	7.0	6.7	34.8	--
11/29	26.7	6.9	4.0	34.0	--
11/30	--	--	--	--	--
平均	26.8	7.0	5.9	36.9	6.5