

92年6月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
06/01	27.4	7.0	4.2	34.1	--
06/02	28.3	6.9	2.7	25.9	--
06/03	29.3	6.9	6.6	47.8	15.4
06/04	28.3	7.0	6.1	51.4	--
06/05	28.6	6.9	4.8	26.9	15.1
06/06	28.6	6.9	3.4	31.2	12.8
06/07	27.9	7.1	ND	31.1	--
06/08	27.6	7.1	4.6	33.4	--
06/09	28.1	7.0	6.7	47.8	14.2
06/10	28.4	6.9	7.0	43.5	11.4
06/11	28.4	7.0	4.8	36.0	16.3
06/12	27.0	7.0	6.7	50.4	12.1
06/13	26.5	7.0	4.7	48.0	16.3
06/14	26.1	7.1	1.3	45.7	--
06/15	26.5	7.1	1.3	47.2	--
06/16	28.9	6.9	2.4	34.6	12.0
06/17	29.1	7.1	5.0	41.3	11.5
06/18	27.9	7.0	6.4	49.4	16.2
06/19	28.5	6.9	5.0	39.9	11.6
06/20	27.7	7.0	2.8	25.9	11.2
06/21	28.1	7.0	3.6	44.7	--
06/22	28.5	7.0	2.7	23.9	--
06/23	29.6	7.0	2.8	27.0	11.9
06/24	28.8	7.0	4.3	37.0	10.8
06/25	29.0	7.0	1.6	28.9	12.3
06/26	28.6	7.0	5.0	32.5	--
06/27	28.2	6.9	3.8	34.5	--
06/28	28.9	7.0	3.0	23.4	--
06/29	29.1	7.0	2.2	39	--
06/30	29.0	7.0	4.3	51.5	--
平均	28.2	7.0	4.1	37.8	13.2