

92年7月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
07/01	28.4	7.2	2.1	33.8	15.2
07/02	29.0	7.1	2.0	32.8	14.6
07/03	28.8	7.0	2.2	21.6	11.3
07/04	29.3	7.0	2.8	19.7	10.4
07/05	29.9	7.0	2.5	19.5	--
07/06	29.0	7.0	2.0	24.2	--
07/07	29.1	7.0	2.9	24.2	18.0
07/08	28.7	7.0	3.5	25.3	15.4
07/09	28.2	7.0	3.3	23.0	15.7
07/10	29.8	7.0	2.4	26.1	11.3
07/11	28.8	7.1	6.6	38.4	16.8
07/12	28.1	7.0	3.2	46.2	--
07/13	28.0	7.0	3.4	32.2	--
07/14	29.2	7.0	4.6	34.3	15.7
07/15	29.5	7.0	3.8	33.2	12.2
07/16	29.4	7.0	4.6	35.7	15.8
07/17	29.4	7.0	4.3	40.5	15.2
07/18	29.1	7.1	4.3	30.6	14.6
07/19	29.8	7.0	0.8	34.8	--
07/20	30.4	7.0	1.2	24.0	--
07/21	29.3	6.9	3.8	32.5	13.9
07/22	29.2	7.0	6.7	48.2	15.3
07/23	29.4	7.0	5.0	21.9	15.5
07/24	29.4	7.0	4.9	47.0	17.0
07/25	29.3	7.0	4.0	46.8	17.5
07/26	28.5	7.0	2.3	28.4	--
07/27	28.4	7.1	2.0	33.0	--
07/28	29.3	7.0	4.0	19.2	--
07/29	29.2	6.9	2.1	37.0	--
07/30	29.1	6.9	7.0	44.7	--
07/31	29.2	6.9	6.8	34.7	--
平均	29.1	7.0	3.6	32.0	14.8