

92年8月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
08/01	29.5	7.0	6.7	44.1	16.5
08/02	28.7	7.0	5.4	44.4	--
08/03	28.6	7.0	5.8	50.0	--
08/04	28.5	7.0	6.8	44.4	16.9
08/05	25.9	6.9	5.5	36.1	15.8
08/06	28.7	7.0	3.1	40.4	15.0
08/07	29.3	7.0	3.0	31.1	17.7
08/08	29.5	6.9	4.8	24.6	15.6
08/09	28.8	6.9	4.6	27.8	--
08/10	29.2	7.0	3.0	13.1	--
08/11	29.9	7.0	4.9	30.6	15.9
08/12	29.8	7.0	6.8	38.2	15.4
08/13	29.6	7.0	4.2	33.7	15.2
08/14	29.7	7.0	4.4	44.3	14
08/15	29.7	7.0	6.7	46.8	15.7
08/16	28.3	7.1	2.5	24.7	--
08/17	28.5	7.1	1.4	38.6	--
08/18	29.5	7.0	4.5	36.2	15.3
08/19	29.6	7.0	5.0	34.9	17.1
08/20	28.8	6.9	3.8	45.9	16.6
08/21	28.9	6.9	3.8	27.2	16.2
08/22	29.1	6.9	4.2	44.7	--
08/23	29.7	7.0	4.2	37.9	--
08/24	29.5	7.0	3.3	40.3	--
08/25	29.2	7.0	5.6	47.4	--
08/26	28.9	7.0	6.6	40.5	--
08/27	29.2	6.9	6.4	30.8	--
08/28	29.2	6.9	4.5	29.0	--
08/29	28.3	6.9	4.1	32.7	--
08/30	28.9	7.1	3.6	19.6	--
08/31	29.3	7.2	3.2	27.4	--
平均	29.0	7.0	4.6	35.7	15.9