

93 年 02 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
2/01	24.1	7.0	3.0	49.5	--
2/02	23.6	7.0	4.0	40.7	20.8
2/03	22.4	7.0	4.9	57.0	20.5
2/04	23.9	7.0	10.4	44.4	25.2
2/05	22.1	7.0	4.0	47.2	22.8
2/06	22.6	7.0	3.0	29.9	18.8
2/07	22.5	7.0	5.1	35.0	--
2/08	21.8	7.1	2.9	37.3	--
2/09	22.8	7.0	4.4	36.5	20.8
2/10	23.1	7.1	4.8	29.6	20.9
2/11	23.6	7.1	2.8	36.9	20.3
2/12	23.5	7.1	3.0	31.7	20.5
2/13	26.7	6.9	3.2	25.2	16.7
2/14	24.1	7.1	2.8	37.9	--
2/15	24.2	7.1	15.0	54.2	--
2/16	24.7	7.1	4.7	49.6	22.5
2/17	24.8	7.1	6.3	30.6	17.7
2/18	24.7	7.1	3.7	55.8	23.2
2/19	24.6	7.1	3.6	42.1	20.4
2/20	25.7	7.0	3.3	52.7	22.4
2/21	25.3	7.1	3.2	34.0	--
2/22	25.4	7.1	2.0	48.2	--
2/23	25.4	7.1	5.9	60.1	23.5
2/24	25.2	7.0	3.6	52.2	22.3
2/25	24.9	7.1	3.1	35.6	18.6
2/26	25.1	7.0	3.4	54.7	22.8
2/27	25.3	7.0	2.8	47.4	--
2/28	26.1	7.0	3.7	55.3	--
2/29	25.6	7.1	4.0	53.7	--
平均	24.3	7.0	4.4	43.6	21.1