

93 年 03 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
03/01	26.5	7.0	3.2	47.4	22.8
03/02	25.2	7.1	3.0	56.7	21.2
03/03	24.4	7.1	3.4	55.9	21.4
03/04	23.2	7.2	4.0	57.8	23.1
03/05	24.8	7.0	4.6	54.9	21.9
03/06	24.4	7.0	2.6	38.7	--
03/07	24.4	7.0	2.2	57.3	--
03/08	23.6	7.0	3.9	51.9	14.6
03/09	23.6	7.2	3.8	45.2	15.2
03/10	24.9	7.1	3.8	45.2	14.8
03/11	26.2	7.2	4.4	55.6	15.3
03/12	26.2	7.2	3.0	61.9	13.9
03/13	26.0	7.0	2.7	49.6	--
03/14	26.0	7.0	3.2	65.3	--
03/15	25.6	7.0	6.0	58.3	14.1
03/16	25.9	7.0	6.0	51.6	13.8
03/17	25.8	7.0	6.6	57.1	13.6
03/18	26.1	7.0	4.6	61.7	14.5
03/19	24.0	7.1	13.3	62.5	13.7
03/20	25.7	7.0	2.3	49.0	--
03/21	25.9	7.0	1.7	52.2	--
03/22	24.5	7.0	4.9	53.7	13.6
03/23	25.4	7.0	5.5	47.2	13.1
03/24	24.5	7.0	7.3	59.1	14.6
03/25	24.7	7.4	5.0	50.2	14.0
03/26	23.9	7.1	4.2	34.7	12.2
03/27	26.8	7.0	3.6	48.0	--
03/28	26.8	7.0	3.6	59.6	--
03/29	24.2	7.1	5.0	60.4	--
03/30	24.2	7.2	5.8	68.2	--
03/31	24.6	7.2	5.2	61.1	--
平均	25.1	7.1	4.5	54.1	16.1