

93 年 04 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
04/01	23.9	7.3	4.8	48.0	11.0
04/02	23.3	7.3	7.4	55.2	13.6
04/03	24.1	7.3	3.4	63.8	--
04/04	23.8	7.1	2.5	61.4	--
04/05	24.1	7.3	6.2	38.5	11.4
04/06	25.7	7.3	6.5	45.5	11.1
04/07	24.8	7.4	10.1	37.9	12.0
04/08	24.2	7.3	5.2	32.5	13.2
04/09	23.7	7.3	5.8	55.0	12.8
04/10	24.5	7.2	4.0	58.7	--
04/11	24.5	7.2	4.2	61.9	--
04/12	25.0	7.2	10.1	62.7	13.2
04/13	25.1	7.4	6.1	52.3	11.6
04/14	24.0	7.2	5.0	35.1	11.4
04/15	25.4	7.1	5.3	53.1	14.3
04/16	24.1	7.2	6.1	54.0	13.6
04/17	25.4	7.0	8.4	59.5	--
04/18	25.3	7.0	5.8	34.9	--
04/19	25.1	7.1	4.8	49.6	13.4
04/20	25.4	7.0	4.1	40.0	10.9
04/21	25.1	7.1	5.6	63.2	15.2
04/22	25.4	7.0	5.2	63.1	15.2
04/23	26.2	7.2	6.0	53.0	13.5
04/24	26.2	7.1	1.6	46.0	--
04/25	26.0	7.0	7.1	51.6	--
04/26	26.4	7.0	4.2	54.4	13.8
04/27	27.0	7.1	5.4	45.8	12.3
04/28	26.1	7.1	6.0	57.3	13.1
04/29	26.8	7.3	5.6	55.8	13.7
04/30	26.2	7.0	5.2	42.5	11.9
平均	25.1	7.2	5.6	51.1	12.8