

93 年 05 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
05/01	27.4	7.1	5.1	48.6	--
05/02	27.1	7.0	6.3	69.0	--
05/03	28.6	7.1	7.1	60.0	14.1
05/04	27.9	7.2	8.0	57.4	11.4
05/05	28.0	7.1	11.1	55.2	13.8
05/06	28.1	7.1	5.9	38.3	11.4
05/07	28.5	7.1	5.1	51.0	13.4
05/08	26.1	7.0	3.5	63.8	--
05/09	26.5	7.0	3.1	55.1	--
05/10	28.6	7.0	4.6	51.2	13.4
05/11	28.4	7.1	4.0	44.3	12.7
05/12	28.2	7.0	5.0	59.8	12.6
05/13	28.1	7.1	4.5	39.2	14.2
05/14	28.0	7.2	8.2	40.5	13.4
05/15	28.3	7.2	5.0	48.0	--
05/16	27.9	7.2	2.0	34.6	--
05/17	28.1	7.1	4.1	41.7	13.9
05/18	27.8	7.1	13.5	52.2	13.7
05/19	27.8	7.0	4.8	57.9	13.4
05/20	27.9	7.1	6.1	47.8	13.6
05/21	26.5	7.0	8.8	63.2	13.2
05/22	27.0	7.1	1.8	56.8	--
05/23	27.3	7.2	4.4	61.6	--
05/24	28.2	7.0	7.9	62.4	12.9
05/25	27.8	7.1	6.6	50.6	11.4
05/26	27.4	7.0	10.1	46.2	13.4
05/27	27.8	7.2	7.3	60.5	13.2
05/28	27.8	7.2	6.2	57.9	13.4
05/29	27.9	7.1	4.9	60.0	--
05/30	27.6	7.0	3.2	55.2	--
05/31	28.2	7.0	4.2	41.6	11.6
平均	27.8	7.1	5.9	52.6	13.1