

## 93 年 09 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
09/01	29.5	7.1	8.7	39.5	10.1
09/02	29.6	7.1	7.9	49.4	9.5
09/03	28.9	7.1	9.4	47.6	12.5
09/04	28.2	7.1	9.8	57.3	--
09/05	28.1	7.1	12.5	54.4	--
09/06	28.8	7.2	12.9	58.1	13.2
09/07	28.8	7.2	12.5	50.6	12.6
09/08	28.5	7.2	11.6	53.0	12.1
09/09	27.4	7.1	10.4	55.5	12.3
09/10	29.0	7.1	14.4	53.4	12.6
09/11	28.4	7.1	16.2	43.5	--
09/12	28.5	7.1	4.2	52.4	--
09/13	28.6	7.2	16.4	52.4	16.5
09/14	28.5	7.0	15.8	54.6	16.6
09/15	28.7	7.0	11.3	45.6	12.9
09/16	28.1	7.1	13.2	51.2	16.2
09/17	28.3	7.2	13.6	49.6	15.6
09/18	28.2	7.0	17.0	64.5	--
09/19	27.8	7.0	7.8	54.2	--
09/20	28.3	7.1	16.2	60.6	20.5
09/21	28.1	7.2	15.5	46.4	15.4
09/22	28.3	7.2	11.8	54.3	17.5
09/23	28.4	7.2	9.2	60.6	20.3
09/24	28.3	7.0	14.6	63.2	21.6
09/25	27.1	7.0	15.0	58.3	--
09/26	27.1	7.0	15.4	64.5	--
09/27	28.5	7.0	16.2	53.7	16.8
09/28	28.7	7.1	15.8	54.1	--
09/29	28.5	7.2	10.7	46.7	17.8
09/30	28.4	7.2	15.0	59.0	20.2
平均	28.4	7.1	12.7	53.6	15.4