

94 年 06 月台南科學工業園區污水處理廠放流水質

| 日期 | Temp (°C) | PH | SS (mg/L) | COD (mg/L) | BOD ₅ (mg/L) |
|------|-----------|-----|-----------|------------|-------------------------|
| 6/01 | 26.2 | 7.0 | 18.8 | 56.7 | 13.6 |
| 6/02 | 26.1 | 7.0 | 17.8 | 54.4 | 14.5 |
| 6/03 | 25.0 | 6.9 | 17.3 | 45.0 | 14.1 |
| 6/04 | 26.4 | 7.0 | 15.4 | 35.8 | -- |
| 6/05 | 26.1 | 7.0 | 12.0 | 35.0 | -- |
| 6/06 | 26.5 | 6.9 | 14.4 | 52.0 | 13.5 |
| 6/07 | 26.1 | 6.9 | 14.6 | 51.6 | 13.8 |
| 6/08 | 26.5 | 7.0 | 14.1 | 44.1 | 13.6 |
| 6/09 | 26.4 | 7.0 | 14.1 | 48.8 | 13.3 |
| 6/10 | 26.2 | 7.0 | 16.8 | 48.8 | 13.1 |
| 6/11 | 24.6 | 7.0 | 15.2 | 40.9 | -- |
| 6/12 | 24.8 | 7.0 | 14.0 | 44.1 | -- |
| 6/13 | 22.5 | 6.9 | 15.6 | 44.1 | 13.2 |
| 6/14 | 26.0 | 7.0 | 14.0 | 39.0 | 12.9 |
| 6/15 | 25.1 | 6.9 | 14.7 | 46.1 | 13.5 |
| 6/16 | 24.6 | 7.0 | 14.6 | 35.1 | 12.8 |
| 6/17 | 24.5 | 7.0 | 13.6 | 44.5 | 13.1 |
| 6/18 | 26.2 | 7.2 | 11.0 | 52.0 | -- |
| 6/19 | 26.2 | 7.0 | 10.8 | 50.4 | -- |
| 6/20 | 26.1 | 7.0 | 9.2 | 42.7 | 12.8 |
| 6/21 | 26.2 | 7.0 | 12.4 | 43.1 | 12.9 |
| 6/22 | 26.0 | 7.1 | 9.3 | 46.8 | 13.2 |
| 6/23 | 26.1 | 7.0 | 14.0 | 36.4 | 13.0 |
| 6/24 | 26.0 | 6.9 | 13.4 | 48.8 | 13.3 |
| 6/25 | 25.9 | 7.0 | 10.0 | 37.2 | -- |
| 6/26 | 26.1 | 7.0 | 8.5 | 37.2 | -- |
| 6/27 | 26.4 | 7.0 | 10.0 | 52.2 | 14.2 |
| 6/28 | 26.1 | 6.9 | 11.2 | 45.6 | 13.7 |
| 6/29 | 26.0 | 7.0 | 10.8 | 44.2 | 13.0 |
| 6/30 | 26.2 | 7.0 | 14.6 | 47.2 | 13.2 |
| | | | | | |
| 平均 | 25.8 | 7.0 | 13.4 | 45.0 | 13.4 |