

94 年 08 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
8/01	27.8	6.9	11.4	38.3	13.3
8/02	27.6	6.8	13.2	35.1	11.6
8/03	28.3	6.9	12.8	43.2	12.2
8/04	28.0	6.8	11.8	49.2	12.6
8/05	27.6	7.0	11.4	38.9	11.3
8/06	27.7	6.9	13.6	50.0	--
8/07	28.2	7.0	18.8	53.1	--
8/08	28.6	6.9	13.0	67.1	14.6
8/09	28.7	6.9	14.6	41.0	11.6
8/10	28.6	7.0	11.9	49.4	12.6
8/11	28.5	6.9	10.2	52.9	13.0
8/12	28.7	6.9	11.1	58.6	13.6
8/13	28.5	6.9	11.4	62.7	--
8/14	28.3	7.0	11.1	44.7	--
8/15	28.7	7.0	11.2	57.6	13.1
8/16	28.7	6.9	11.6	46.1	12.8
8/17	28.7	7.0	11.2	44.9	12.2
8/18	28.2	6.9	11.4	41.8	11.8
8/19	28.2	6.9	12.6	35.1	11.2
8/20	28.2	7.0	12.4	57.5	--
8/21	28.4	7.1	12.8	44.5	--
8/22	28.6	6.9	12.0	40.9	11.5
8/23	27.6	6.9	11.5	50.8	12.4
8/24	28.3	6.9	12.6	44.7	12.0
8/25	28.5	6.9	11.4	59.6	14.0
8/26	28.7	7.0	14.8	60.9	14.2
8/27	28.5	6.9	10.4	52.2	--
8/28	28.7	7.0	10.0	45.1	--
8/29	28.7	7.1	10.2	38.3	13.3
8/30	28.8	6.9	12.5	45.1	12.5
8/31	28.4	6.9	13.4	39.2	13.7
平均	28.4	6.9	12.2	48.0	12.7