

95 年 01 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
1/01	24.6	6.8	9.4	59.7	--
1/02	23.6	6.8	12.5	49.2	13.4
1/03	25.6	6.9	10.1	44.4	12.6
1/04	24.8	7.0	10.2	54.0	14.0
1/05	24.7	6.9	8.5	48.4	13.0
1/06	23.7	6.9	10.3	61.0	15.3
1/07	23.1	6.9	10.8	47.2	--
1/08	24.6	7.0	8.1	51.2	--
1/09	23.8	6.9	10.4	50.0	13.8
1/10	24.5	6.9	13.8	46.8	12.4
1/11	24.6	6.9	9.6	57.1	14.4
1/12	24.6	6.9	8.0	37.7	12.1
1/13	24.7	6.8	11.2	46.8	12.5
1/14	24.0	7.0	7.3	54.8	--
1/15	23.7	7.0	8.3	38.1	--
1/16	25.2	6.9	9.5	55.2	14.6
1/17	24.6	6.8	10.8	50.0	13.8
1/18	25.1	7.0	8.4	56.3	14.9
1/19	24.8	6.8	4.0	36.8	11.8
1/20	25.5	6.9	5.5	41.5	12.2
1/21	25.1	6.9	16.6	51.8	--
1/22	24.8	6.7	13.2	53.4	--
1/23	23.6	6.9	10.1	46.1	--
1/24	23.2	6.8	10.6	56.6	--
1/25	24.6	6.9	12.2	42.2	--
1/26	24.1	6.8	11.0	48.8	--
1/27	24.6	6.9	8.9	39.6	--
1/28	24.4	6.8	8.8	59.2	--
1/29	24.2	6.8	8.1	60.0	--
1/30	24.5	6.9	7.9	55.6	--
1/31	25.0	6.9	9.0	52.8	--
平均	24.4	6.9	9.8	50.1	13.4