

95 年 06 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
6/01	27.4	6.7	8.1	46.4	13.7
6/02	26.4	6.8	7.1	34.9	13.6
6/03	26.0	7.0	13.8	40.6	--
6/04	27.0	6.9	12.3	36.7	--
6/05	27.3	6.9	13.4	44.2	17.6
6/06	27.4	6.8	13.8	41.3	18.2
6/07	26.6	6.8	15.6	39.8	14.2
6/08	27.3	6.8	10.1	42.9	15.8
6/09	26.4	6.7	9.8	46.8	15.1
6/10	23.1	6.9	9.2	49.2	--
6/11	22.9	6.9	ND	48.0	--
6/12	26.5	6.8	6.9	55.1	18.5
6/13	26.7	6.7	7.8	44.7	12.8
6/14	27.4	6.8	7.8	36.9	16.4
6/15	27.5	6.8	12.1	45.9	16.4
6/16	27.7	6.8	8.0	41.9	16.7
6/17	26.4	6.9	6.3	41.8	--
6/18	26.7	6.9	6.0	43.0	--
6/19	27.7	6.8	9.2	44.2	15.4
6/20	27.6	6.8	12.2	43.0	15.8
6/21	27.6	6.8	4.7	43.5	14.1
6/22	27.6	6.9	6.6	45.4	13.3
6/23	27.6	6.7	4.1	41.6	13.9
6/24	28.2	6.8	2.4	42.2	--
6/25	28.3	6.8	4.2	30.5	--
6/26	28.3	6.7	10.0	32.0	15.9
6/27	28.5	6.8	8.6	53.9	15.3
6/28	28.6	6.8	6.3	45.6	15.1
6/29	28.6	6.8	10.0	45.6	16.2
6/30	28.6	6.7	7.9	34.1	15.3
平均	27.1	6.8	8.8	42.7	15.4