

95 年 07 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
7/01	28.0	7.0	10.1	27.7	--
7/02	28.0	7.0	11.1	36.9	--
7/03	28.6	6.9	13.4	21.3	12.8
7/04	28.4	6.7	12.1	40.7	14.5
7/05	28.6	6.6	11.3	41.6	15.8
7/06	29.2	6.9	5.6	36.3	13.6
7/07	28.3	7.0	7.1	47.6	17.8
7/08	26.4	6.8	9.1	42.1	--
7/09	26.4	6.9	11.2	41.3	--
7/10	28.4	7.0	8.1	40.5	15.3
7/11	26.6	7.0	6.5	34.1	12.7
7/12	28.4	6.8	8.5	36.5	15.8
7/13	26.5	6.9	6.9	47.0	11.7
7/14	26.4	6.9	7.7	33.3	14.3
7/15	26.3	6.8	4.1	36.0	--
7/16	26.3	6.9	3.4	33.6	--
7/17	27.3	6.8	7.2	45.2	15.2
7/18	28.6	6.8	4.7	22.4	14.1
7/19	28.5	6.9	8.5	46.2	15.9
7/20	28.6	7.3	12.8	45.6	14.4
7/21	29.4	6.9	7.5	40.5	14.6
7/22	26.6	6.8	8.9	35.4	--
7/23	26.7	6.8	8.4	41.3	--
7/24	28.4	6.8	8.6	34.2	15.5
7/25	26.5	6.7	10.2	41.7	14.8
7/26	26.4	6.7	12.2	44.5	14.3
7/27	27.3	6.7	11.3	31.2	15.0
7/28	28.4	6.8	10.5	37.1	14.7
7/29	28.5	6.9	11.0	47.4	--
7/30	27.5	6.8	10.9	43.8	--
7/31	28.5	6.8	13.0	46.2	15.7
平均	27.7	6.9	9.1	38.7	14.7