

95 年 09 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
9/01	28.4	6.9	5.3	41.0	13.8
9/02	27.3	6.9	7.4	34.1	--
9/03	27.6	6.9	5.0	31.7	--
9/04	28.5	7.0	3.6	34.1	12.9
9/05	28.2	6.9	5.3	34.8	12.4
9/06	28.4	6.9	3.6	31.6	12.0
9/07	27.4	7.0	4.5	31.2	11.6
9/08	28.5	6.9	4.7	33.3	13.0
9/09	27.3	6.9	6.1	48.6	--
9/10	27.2	7.0	6.2	31.6	--
9/11	28.2	7.0	5.0	45.5	14.0
9/12	28.2	6.8	3.0	39.0	13.4
9/13	28.5	6.9	3.1	34.7	12.6
9/14	28.5	7.0	3.2	30.2	11.8
9/15	29.0	7.0	6.0	37.4	13.0
9/16	28.1	7.0	5.1	40.1	--
9/17	28.1	7.0	5.2	41.7	--
9/18	28.5	7.0	3.9	34.6	13.0
9/19	28.3	6.9	4.8	35.1	12.6
9/20	28.2	6.9	4.2	36.8	13.1
9/21	28.2	6.9	5.2	39.0	13.5
9/22	28.5	6.9	5.3	37.8	13.3
9/23	28.0	7.0	2.6	36.5	--
9/24	28.6	6.9	2.2	30.7	--
9/25	28.5	7.1	4.2	44.2	13.6
9/26	28.2	7.0	3.6	39.0	13.1
9/27	28.5	7.0	5.9	36.1	13.9
9/28	28.7	6.9	4.3	33.2	13.4
9/29	28.5	7.0	5.1	34.1	12.1
9/30	27.6	6.9	4.6	33.3	--
平均	28.2	6.9	4.6	36.4	13.0