

96 年 01 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
01/01	24.6	6.8	5.6	36.3	--
01/02	24.3	6.8	4.4	36.3	11.1
01/03	24.3	6.8	7.1	32.9	11.3
01/04	24.5	6.9	2.9	39.2	13.0
01/05	23.5	6.9	5.3	33.6	10.8
01/06	23.6	6.9	5.9	43.6	--
01/07	24.0	6.9	5.8	30.2	--
01/08	24.4	6.8	5.5	31.7	9.2
01/09	24.4	6.8	5.0	30.7	9.5
01/10	24.5	6.9	6.5	32.1	14.9
01/11	24.6	6.8	5.3	34.3	9.6
01/12	24.7	6.9	6.1	30.1	9.0
01/13	25.3	6.9	8.1	38.2	--
01/14	25.2	6.9	5.7	51.2	--
01/15	25.2	6.9	5.3	50.0	13.4
01/16	24.4	6.9	5.4	35.2	9.6
01/17	24.2	6.9	8.6	30.8	8.4
01/18	23.6	6.9	7.0	34.5	9.0
01/19	23.6	6.9	4.3	31.0	8.8
01/20	24.4	7.0	6.5	43.3	--
01/21	24.0	6.9	6.0	31.0	--
01/22	24.3	6.9	5.3	32.5	9.7
01/23	23.5	6.9	6.2	40.5	12.6
01/24	23.6	6.9	6.5	40.6	8.0
01/25	23.6	6.9	9.3	37.9	12.7
01/26	23.5	6.9	6.8	39.5	11.2
01/27	23.6	7.0	5.2	44.2	--
01/28	23.4	7.0	4.6	49.0	--
01/29	23.2	6.9	7.2	31.3	10.3
01/30	24.2	6.9	6.4	34.4	13.0
01/31	24.4	6.9	5.6	35.7	10.9
平均	24.1	6.9	6.0	36.8	10.7