

96 年 07 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
07/01	28.0	7.0	6.1	38.7	--
07/02	28.7	7.0	6.9	41.1	10.6
07/03	29.5	7.0	5.7	37.8	10.6
07/04	29.5	7.0	8.3	34.4	10.2
07/05	28.7	6.9	7.6	34.1	10.1
07/06	28.6	6.9	7.4	32.5	10.0
07/07	28.0	7.0	7.3	43.1	--
07/08	28.5	7.0	6.4	41.6	--
07/09	28.5	6.9	6.2	32.5	10.1
07/10	28.2	6.9	9.1	35.0	10.4
07/11	28.8	6.9	9.4	32.9	10.2
07/12	28.5	7.0	5.1	31.9	10.1
07/13	29.4	7.0	7.3	30.1	10.0
07/14	28.5	6.9	10.2	50.8	--
07/15	27.8	7.0	6.1	46.1	--
07/16	28.4	7.0	6.6	41.4	10.6
07/17	28.6	7.0	6.6	45.9	10.8
07/18	28.5	6.9	6.8	42.8	10.7
07/19	27.1	7.0	7.4	39.3	10.2
07/20	27.9	7.0	5.5	39.4	10.3
07/21	29.3	7.0	7.3	40.5	--
07/22	29.6	7.0	7.6	36.5	--
07/23	29.6	6.9	8.9	42.1	10.6
07/24	29.0	7.0	8.1	42.7	10.7
07/25	29.3	6.9	6.6	43.1	12.0
07/26	29.4	7.0	7.3	41.4	10.5
07/27	29.2	6.9	6.9	36.5	10.2
07/28	29.6	6.9	7.1	48.0	--
07/29	29.5	6.9	6.4	49.5	--
07/30	29.6	6.9	6.1	38.1	10.5
07/31	29.3	7.0	7.6	32.8	9.8
平均	28.8	7.0	7.2	39.4	10.4