

96 年 08 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
08/01	29.6	6.9	6.9	40.0	11.2
08/02	29.5	6.9	5.1	36.0	10.2
08/03	29.3	6.9	9.0	38.6	11.0
08/04	28.8	6.9	8.3	42.9	--
08/05	29.0	6.9	8.7	37.5	--
08/06	28.9	7.0	7.6	40.2	11.2
08/07	29.0	7.0	8.8	35.9	10.1
08/08	28.3	7.0	8.4	39.2	11.0
08/09	27.3	7.0	9.0	38.4	11.4
08/10	27.7	6.9	8.3	32.9	12.0
08/11	26.0	6.9	10.7	40.6	--
08/12	25.9	7.0	9.4	44.5	--
08/13	26.3	6.9	12.6	44.9	11.3
08/14	26.3	7.0	8.7	35.1	10.3
08/15	26.5	6.9	12.7	45.9	11.4
08/16	28.6	6.8	7.1	44.0	11.2
08/17	28.9	6.9	8.7	42.2	11.3
08/18	26.3	6.7	8.5	43.4	--
08/19	26.4	6.8	8.3	33.3	--
08/20	26.5	6.9	12.6	34.1	9.2
08/21	26.5	6.9	10.6	31.0	10.2
08/22	26.3	7.0	6.9	40.4	11.0
08/23	27.6	7.0	8.8	33.6	9.5
08/24	28.5	7.0	9.3	41.4	11.3
08/25	27.6	7.0	10.6	35.0	--
08/26	27.6	6.9	6.8	41.9	--
08/27	28.5	7.0	8.8	35.8	9.6
08/28	28.7	7.0	7.3	39.8	9.8
08/29	29.4	7.0	9.0	44.4	11.3
08/30	29.4	7.0	10.5	33.2	9.5
08/31	29.4	7.0	9.0	33.7	9.7
平均	27.9	6.9	8.9	38.7	10.6