

96 年 09 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
09/01	28.9	7.0	10.3	48.4	--
09/02	28.4	6.9	4.1	42.9	--
09/03	29.5	7.0	6.8	36.9	9.8
09/04	28.6	7.0	8.5	45.8	11.2
09/05	28.4	7.0	10.6	38.5	10.1
09/06	28.4	7.0	7.9	44.1	11.0
09/07	29.3	7.1	10.5	45.9	11.8
09/08	28.3	6.9	9.8	37.0	--
09/09	28.5	7.0	8.5	32.4	--
09/10	28.7	7.0	8.5	36.2	9.9
09/11	29.4	7.1	11.4	53.9	12.2
09/12	29.0	6.9	10.2	57.6	12.5
09/13	29.5	7.0	10.1	40.8	11.7
09/14	29.5	7.1	6.4	39.7	11.5
09/15	28.9	7.0	5.6	35.5	--
09/16	28.4	6.9	7.9	33.2	--
09/17	27.5	7.0	7.6	35.9	--
09/18	28.3	7.0	9.8	36.8	--
09/19	28.4	7.1	10.2	34.9	--
09/20	28.5	7.0	7.3	37.5	11.0
09/21	28.6	7.0	9.0	53.9	12.2
09/22	28.3	6.8	6.4	38.4	--
09/23	28.0	6.9	4.6	31.5	--
09/24	27.4	6.9	6.4	31.1	--
09/25	27.5	6.9	6.6	53.8	--
09/26	28.8	7.0	5.7	34.6	9.8
09/27	29.4	6.9	6.0	37.7	10.1
09/28	29.7	6.9	5.1	35.1	9.9
09/29	29.6	6.9	4.6	41.6	10.3
09/30	29.5	6.9	7.7	37.1	--
平均	28.7	7.0	7.8	40.3	10.9