

96 年 11 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/01	28.5	6.9	5.4	37.2	10.1
11/02	27.4	6.9	5.5	42.6	11.9
11/03	27.2	6.9	5.1	34.0	--
11/04	26.7	6.9	4.6	31.6	--
11/05	27.2	6.9	5.6	30.4	10.9
11/06	27.3	6.9	5.9	35.1	12.5
11/07	26.3	6.9	7.6	46.0	12.4
11/08	26.3	6.9	5.7	35.2	10.3
11/09	26.1	6.9	7.3	39.3	11.3
11/10	26.3	7.0	7.6	42.9	--
11/11	26.0	7.0	6.4	39.8	--
11/12	26.3	6.9	5.8	39.0	11.4
11/13	26.3	7.0	5.3	38.6	11.0
11/14	26.9	6.9	4.5	36.9	10.5
11/15	26.7	7.0	6.1	45.1	12.1
11/16	26.2	6.9	6.9	37.2	10.4
11/17	23.8	6.8	5.7	44.5	--
11/18	23.8	7.0	6.9	40.9	--
11/19	26.1	6.9	4.8	35.0	11.4
11/20	25.8	6.9	4.6	37.3	10.2
11/21	26.2	6.8	6.6	34.4	10.1
11/22	26.2	6.8	4.0	43.4	12.2
11/23	25.6	6.9	6.0	39.3	12.1
11/24	26.1	6.9	4.4	41.1	--
11/25	26.0	6.9	5.0	39.9	--
11/26	25.8	6.8	5.1	39.5	11.5
11/27	24.5	6.8	5.7	39.4	9.8
11/28	24.3	6.9	6.8	38.8	11.3
11/29	25.3	6.9	7.1	33.9	10.2
11/30	24.3	6.9	4.8	34.1	11.8
平均	26.1	6.9	5.8	38.4	11.2