

96 年 12 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
12/01	24.7	6.9	3.6	37.3	--
12/02	25.0	6.8	6.1	38.1	--
12/03	24.3	6.8	3.9	37.7	10.1
12/04	24.4	6.9	4.6	38.5	11.4
12/05	24.0	6.9	7.0	38.9	10.8
12/06	25.0	6.9	5.1	38.8	10.7
12/07	25.1	6.8	6.1	38.2	11.3
12/08	24.4	6.8	6.0	35.7	--
12/09	25.0	6.8	6.3	40.5	--
12/10	24.5	6.8	8.1	43.2	9.9
12/11	25.2	6.9	8.5	43.0	11.3
12/12	24.8	6.9	7.4	43.4	10.8
12/13	24.5	6.8	5.3	38.6	12.8
12/14	25.4	6.9	5.9	37.0	12.1
12/15	25.3	7.0	7.8	39.3	--
12/16	25.4	6.9	7.0	39.3	--
12/17	25.2	6.9	6.2	38.1	10.7
12/18	25.3	6.9	6.6	43.6	11.2
12/19	25.0	6.9	5.8	32.1	10.8
12/20	25.2	6.9	6.4	34.5	11.3
12/21	25.6	6.9	4.6	35.6	11.6
12/22	26.1	6.9	6.3	46.8	--
12/23	25.9	6.9	5.9	37.4	--
12/24	25.5	6.9	7.5	40.5	10.6
12/25	24.4	6.8	4.5	31.9	11.3
12/26	25.3	6.9	9.4	34.9	12.3
12/27	24.4	7.0	5.5	34.0	12.0
12/28	25.4	7.0	8.7	39.7	12.1
12/29	24.5	6.9	8.1	37.1	--
12/30	24.1	6.8	6.6	37.9	--
12/31	23.2	7.0	6.4	36.4	9.4
平均	24.9	6.9	6.4	38.3	11.2

