

97 年 06 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
06/01	27.4	6.9	4.8	33.3	--
06/02	27.3	6.9	5.6	34.9	7.9
06/03	27.2	7.0	4.1	36.1	10.0
06/04	26.6	6.8	3.6	34.4	11.8
06/05	26.5	6.9	5.5	33.6	10.8
06/06	26.5	6.9	4.2	36.4	12.9
06/07	26.3	6.8	3.9	37.8	--
06/08	25.9	6.9	4.6	35.7	--
06/09	27.1	6.9	5.8	30.9	11.3
06/10	27.2	6.9	6.0	40.0	10.8
06/11	27.2	6.8	6.5	32.0	12.4
06/12	27.0	6.9	4.7	39.8	11.4
06/13	27.5	6.9	5.1	39.3	12.2
06/14	26.2	6.8	5.6	46.6	--
06/15	26.7	6.9	4.0	41.0	--
06/16	26.3	7.0	4.7	39.4	11.4
06/17	26.5	6.9	5.6	34.0	10.6
06/18	27.6	6.9	4.7	30.3	11.8
06/19	27.4	6.8	5.4	32.9	10.9
06/20	27.5	6.7	6.7	36.3	12.7
06/21	27.2	6.8	6.6	37.7	--
06/22	27.2	6.9	4.9	36.1	--
06/23	27.6	6.9	5.2	32.5	10.9
06/24	27.6	6.8	4.2	30.4	10.2
06/25	26.6	6.8	6.7	31.1	11.7
06/26	27.6	6.8	6.0	33.5	11.3
06/27	26.7	7.0	5.6	39.3	12.5
06/28	27.0	7.0	4.7	36.3	--
06/29	27.3	6.9	5.6	47.0	--
06/30	26.6	6.9	4.2	38.6	12.0
平均	27.0	6.9	5.2	36.2	11.3