

97 年 09 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
09/01	27.5	6.8	4.3	41.7	9.2
09/02	27.3	6.8	5.0	44.0	10.0
09/03	27.1	6.8	6.2	30.0	8.0
09/04	27.8	6.9	4.6	35.5	8.6
09/05	28.5	6.9	5.6	39.8	10.8
09/06	27.4	6.9	5.0	35.5	--
09/07	27.5	7.0	5.3	37.1	--
09/08	28.4	6.7	6.0	40.2	10.8
09/09	28.2	6.8	5.0	41.4	9.2
09/10	28.3	6.8	6.2	39.4	11.0
09/11	26.7	6.8	6.0	41.0	10.1
09/12	27.8	6.7	5.3	35.3	8.8
09/13	26.7	6.9	6.0	30.3	--
09/14	26.7	7.0	5.7	33.5	--
09/15	27.1	6.6	6.0	34.3	8.4
09/16	27.3	6.8	5.8	33.7	9.4
09/17	27.5	6.7	6.2	35.7	8.0
09/18	27.7	6.7	5.3	30.9	9.6
09/19	27.3	6.6	5.6	36.5	9.2
09/20	28.0	6.8	5.8	38.4	--
09/21	28.3	6.9	5.0	48.8	--
09/22	27.2	6.7	5.3	36.8	9.0
09/23	27.6	6.8	6.0	45.4	8.9
09/24	27.8	6.7	6.8	30.7	7.5
09/25	28.3	6.9	5.8	35.3	9.1
09/26	27.5	6.7	5.2	38.5	8.8
09/27	28.2	6.8	4.7	42.2	--
09/28	27.2	6.8	4.2	36.5	--
09/29	27.8	6.7	8.9	31.7	--
09/30	27.0	6.6	5.0	31.7	7.6
平均	27.6	6.8	5.6	37.1	9.1