

## 97 年 10 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
10/01	27.5	6.5	5.0	30.8	7.6
10/02	27.7	6.7	5.8	37.1	8.5
10/03	27.5	6.5	4.8	31.3	9.0
10/04	27.6	6.6	5.3	30.3	--
10/05	27.5	6.5	6.0	34.3	--
10/06	28.3	6.3	5.8	31.5	9.0
10/07	27.6	6.5	6.2	31.3	8.6
10/08	27.7	6.6	6.8	37.1	9.5
10/09	27.6	6.5	5.7	30.7	7.5
10/10	27.2	7.0	6.0	42.1	--
10/11	27.3	6.9	5.8	31.7	--
10/12	27.6	6.9	5.0	49.2	--
10/13	27.2	6.5	6.2	35.7	8.7
10/14	27.5	6.7	4.8	34.0	8.0
10/15	27.6	6.5	5.0	34.3	8.7
10/16	27.4	6.6	6.0	39.4	9.4
10/17	27.8	6.7	5.0	35.3	8.8
10/18	27.3	6.9	6.4	37.7	--
10/19	27.2	6.9	4.4	36.9	--
10/20	27.6	6.6	5.4	36.1	8.4
10/21	27.7	6.7	5.2	43.1	9.0
10/22	27.8	6.7	6.4	36.4	9.5
10/23	27.7	6.6	5.4	31.9	7.5
10/24	28.0	6.7	5.0	31.5	8.4
10/25	28.0	6.8	5.8	37.1	--
10/26	27.1	6.6	4.8	33.1	--
10/27	27.5	6.5	6.0	35.5	7.1
10/28	27.6	6.6	5.1	37.3	8.6
10/29	27.3	6.6	4.8	36.1	9.0
10/30	27.5	6.3	6.8	30.8	8.0
10/31	27.4	6.5	5.4	30.7	7.0
平均	27.6	6.6	5.6	35.2	8.4