

97 年 11 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/01	27.9	6.9	5.2	31.5	--
11/02	28.0	7.0	4.1	37.8	--
11/03	28.4	6.5	5.3	37.1	7.7
11/04	27.6	6.5	5.7	34.4	6.6
11/05	27.0	6.5	5.8	31.1	6.7
11/06	27.4	6.4	5.6	30.3	5.9
11/07	27.9	6.5	5.8	31.7	6.2
11/08	26.7	6.6	5.8	30.6	--
11/09	26.5	6.7	4.8	40.1	--
11/10	25.9	6.5	6.0	38.9	7.0
11/11	22.0	6.6	5.6	44.4	6.2
11/12	25.7	6.5	4.4	44.7	6.0
11/13	26.0	6.7	5.2	37.7	5.8
11/14	26.3	6.7	6.0	41.6	6.3
11/15	24.9	6.9	4.2	31.7	--
11/16	24.9	7.0	5.0	38.1	--
11/17	26.2	6.6	5.4	36.9	6.8
11/18	25.9	6.7	4.8	32.9	6.3
11/19	25.2	6.7	5.2	30.4	6.1
11/20	24.6	6.7	5.7	34.0	5.4
11/21	24.5	6.9	5.3	34.1	5.5
11/22	25.1	7.2	6.0	32.4	--
11/23	25.0	7.2	5.4	32.8	--
11/24	25.2	6.6	5.0	30.4	6.2
11/25	25.5	6.7	4.6	38.4	5.9
11/26	25.3	6.7	6.0	30.1	6.3
11/27	25.3	6.8	4.2	30.7	5.8
11/28	25.5	6.7	6.0	31.5	7.0
11/29	24.8	7.2	6.2	42.6	--
11/30	24.9	7.1	5.4	45.0	--
平均	25.9	6.7	5.3	35.5	6.3