

98 年 02 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
02/01	23.8	7.0	5.2	32.1	--
02/02	24.1	6.7	4.6	35.7	5.5
02/03	24.3	6.7	4.5	31.6	4.4
02/04	24.2	6.6	4.8	34.4	5.9
02/05	24.4	6.7	5.4	35.2	4.6
02/06	24.5	6.6	4.2	35.5	5.3
02/07	23.8	6.7	4.6	36.1	--
02/08	24.0	6.7	5.2	32.9	--
02/09	24.6	6.7	5.6	33.3	5.3
02/10	24.3	6.7	4.6	31.0	5.4
02/11	24.8	6.7	5.0	32.4	6.4
02/12	25.1	6.6	5.4	34.4	5.5
02/13	25.4	6.7	4.3	33.1	5.8
02/14	24.6	7.0	5.3	32.7	--
02/15	24.0	7.0	4.8	35.9	--
02/16	25.4	6.6	5.6	34.3	5.9
02/17	25.3	6.8	4.4	33.7	4.3
02/18	24.9	6.8	4.2	30.8	5.0
02/19	25.2	6.7	4.6	31.2	5.6
02/20	25.6	6.9	4.4	33.2	6.5
02/21	25.9	7.0	4.6	33.5	--
02/22	26.0	7.0	5.2	31.9	-
02/23	25.9	6.6	5.0	32.3	5.8
02/24	26.2	6.6	5.3	30.6	6.0
02/25	26.1	6.8	3.4	30.0	4.3
02/26	25.9	6.8	3.3	30.8	4.0
02/27	25.8	6.7	4.2	30.4	4.8
02/28	25.7	7.0	3.7	31.5	
平均	25.0	6.8	4.7	32.9	5.3