

98 年 05 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
05/01	26.4	6.9	4.3	33.6	5.2
05//02	26.4	6.9	5.0	34.1	--
05/03	26.5	6.9	4.7	33.3	--
05/04	26.6	6.8	5.2	31.0	4.7
05/05	26.9	6.8	4.0	30.1	5.1
05/06	26.7	6.8	4.6	31.2	4.8
05/07	26.5	6.9	4.4	33.9	5.6
05/08	26.7	6.9	4.2	31.7	5.2
05/09	25.1	7.0	5.4	32.8	--
05/10	25.0	7.0	4.7	32.0	--
05/11	26.6	6.8	5.0	30.8	5.0
05/12	26.8	6.9	4.6	31.2	5.5
05/13	27.5	6.9	3.8	30.4	4.9
05/14	27.6	6.7	5.0	30.7	5.7
05/15	27.6	6.8	5.1	33.2	5.5
05/16	28.5	7.0	4.7	29.0	--
05/17	28.3	7.0	4.4	32.1	--
05/18	27.5	6.9	5.6	34.5	5.9
05/19	27.4	6.8	5.0	31.2	4.8
05/20	27.7	6.8	4.6	30.3	6.1
05/21	27.9	7.0	4.2	34.6	5.2
05/22	27.9	6.8	4.4	30.4	4.6
05/23	28.8	7.0	4.6	30.0	--
05/24	28.8	6.9	3.3	31.6	--
05/25	27.4	7.0	4.6	34.8	5.2
05/26	27.1	6.7	4.2	30.4	4.7
05/27	27.6	7.0	3.6	27.3	5.4
05/28	25.8	6.9	3.6	30.3	--
05/29	25.3	7.0	4.1	33.5	--
05/30	25.9	6.9	4.5	35.0	--
05/31	25.8	7.0	3.5	29.9	--
平均	27.0	6.9	4.5	31.8	5.2