

## 98 年 08 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
08/01	30.1	6.8	4.2	32.1	--
08//02	28.4	6.9	4.9	30.6	--
08/03	28.3	6.6	3.6	30.2	4.6
08/04	28.3	6.8	4.4	30.4	5.6
08/05	28.2	6.8	4.2	30.2	5.8
08/06	28.0	6.9	3.7	29.9	4.7
08/07	24.1	6.8	4.7	35.7	--
08/08	24.1	6.9	4.2	30.2	--
08/09	23.9	6.9	5.1	34.1	--
08/10	27.8	6.8	4.2	30.2	4.4
08/11	28.1	6.8	4.2	50.6	6.0
08/12	28.0	6.8	4.4	30.4	5.2
08/13	27.5	6.8	3.9	29.9	4.0
08/14	27.8	6.8	3.6	32.1	4.9
08/15	26.9	7.7	5.0	30.8	--
08/16	26.4	7.7	3.8	31.6	--
08/17	28.2	6.8	4.2	29.2	4.7
08/18	28.0	6.7	3.2	30.9	5.7
08/19	27.9	6.7	3.8	31.0	4.9
08/20	28.1	7.1	3.5	30.1	5.5
08/21	28.3	6.7	3.7	33.3	5.3
08//22	27.8	6.8	4.4	30.4	--
08/23	28.1	6.7	4.0	31.2	--
08/24	28.6	6.7	3.6	32.4	4.8
08/25	28.4	6.8	5.1	30.0	5.6
08/26	28.5	6.8	4.3	29.6	4.7
08/27	28.5	6.7	4.2	30.3	5.5
08/28	28.4	6.8	4.3	34.1	4.9
08/29	25.9	6.9	4.6	31.7	--
08/30	26.6	6.9	3.4	31.0	--
08/31	27.9	6.7	4.5	30.2	5.2
平均	27.6	6.9	4.2	31.8	5.1