

98 年 10 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
10/01	28.0	6.8	2.6	34.1	4.5
10//02	27.9	6.7	2.9	27.0	5.7
10/03	27.5	6.8	3.8	30.2	--
10/04	27.6	6.9	3.4	32.5	--
10/05	27.0	6.7	3.2	34.5	6.4
10//06	27.3	6.8	4.3	27.5	6.0
10/07	27.0	6.8	5.1	26.2	4.7
10/08	27.0	6.7	3.4	32.5	4.2
10/09	27.4	6.8	1.6	34.0	6.5
10/10	28.9	6.9	2.3	39.8	--
10/11	28.7	6.8	1.8	39.0	--
10/12	27.5	6.8	1.2	30.7	4.5
10/13	27.6	6.8	2.4	30.2	6.2
10/14	27.5	6.7	2.8	25.4	5.4
10/15	27.3	6.7	2.6	30.0	5.9
10/16	27.2	6.7	2.6	27.2	6.3
10/17	26.9	6.9	2.0	27.0	--
10/18	27.5	6.9	3.1	30.2	--
10/19	27.2	6.7	3.0	27.0	9.4
10/20	27.5	6.7	2.0	37.3	5.1
10/21	26.9	6.7	2.1	26.1	5.4
10//22	26.8	6.7	4.1	30.0	6.0
10/23	26.9	6.6	3.8	31.5	4.7
10/24	26.4	6.8	2.4	25.4	--
10/25	26.9	6.9	2.0	34.1	--
10/26	26.5	6.8	3.7	27.8	4.9
10/27	26.8	6.7	3.9	31.3	6.2
10/28	27.0	6.7	3.0	25.3	6.0
10/29	27.0	6.7	3.6	30.3	6.2
10/30	26.9	6.7	3.9	27.1	5.1
10/31	26.7	7.0	4.0	36.5	--
平均	27.3	6.8	3.0	30.6	5.7