

## 99 年 01 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
01/01	24.8	6.7	2.7	32.9	--
01//02	24.2	6.8	2.0	39.4	--
01/03	25.6	6.9	4.6	36.5	--
01/04	23.9	6.8	5.0	39.0	6.4
01/05	24.0	6.7	2.5	35.5	5.4
01//06	24.1	6.7	4.1	35.5	8.0
01/07	23.9	6.8	2.5	40.6	6.4
01/08	24.2	6.8	8.3	38.9	6.7
01/09	24.6	6.9	6.2	32.5	--
01/10	24.1	6.9	3.6	34.5	--
01/11	23.9	6.7	2.8	32.1	7.4
01/12	23.5	6.7	1.8	34.0	8.6
01/13	23.4	6.8	7.5	35.1	7.4
01/14	23.7	6.7	3.4	35.9	6.7
01/15	23.9	6.8	3.0	35.7	6.0
01/16	23.9	6.8	3.2	37.1	--
01/17	24.0	6.9	2.8	33.2	--
01/18	24.4	6.7	5.0	35.2	6.9
01/19	24.3	6.8	6.5	37.6	6.0
01/20	24.8	6.7	12.0	44.8	8.3
01/21	25.2	6.7	8.2	36.7	6.3
01/22	24.9	6.8	2.0	31.1	7.4
01/23	24.7	6.9	3.0	32.5	--
01/24	24.5	6.8	2.1	32.5	--
01/25	25.1	6.8	8.9	33.7	7.3
01/26	24.1	6.7	8.0	30.4	5.8
01/27	24.0	6.8	12.0	34.4	6.9
01/28	25.1	6.8	10.7	34.7	5.8
01/29	25.1	6.7	7.4	36.3	6.7
01/30	26.0	6.8	6.8	33.7	--
01/31	25.9	6.8	5.4	34.5	--
平均	24.4	6.8	5.3	35.4	6.8