

99 年 07 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
07/01	28.5	6.4	5.9	35.7	6.8
07//02	28.4	6.7	6.1	36.5	7.8
07/03	26.1	6.8	5.6	32.7	--
07/04	26.3	6.8	6.2	31.5	--
07/05	28.4	6.7	7.1	34.4	6.5
07//06	28.3	6.7	5.3	36.3	8.8
07/07	28.5	6.8	8.6	32.1	7.5
07/08	27.8	6.7	4.7	35.3	8.6
07/09	28.6	6.7	3.4	32.5	8.1
07/10	27.8	6.9	2.4	36.4	--
07/11	28.0	6.9	4.6	35.6	--
07/12	28.4	6.9	5.0	35.6	7.5
07/13	28.1	6.8	4.5	31.1	6.8
07/14	28.1	6.8	4.0	36.3	7.9
07/15	28.1	6.8	4.1	33.3	8.5
07/16	28.2	6.7	8.1	29.0	6.1
07/17	27.0	6.8	4.0	34.4	--
07/18	27.8	6.9	5.6	31.6	--
07/19	27.6	6.8	4.0	36.4	7.5
07/20	28.1	6.8	3.8	29.1	8.3
07/21	28.3	6.8	4.1	34.5	7.9
07/22	27.9	6.8	5.0	31.7	7.0
07/23	28.0	6.8	5.1	33.2	8.4
07/24	29.4	6.9	6.0	34.4	--
07/25	29.2	6.9	5.3	29.6	--
07/26	27.6	6.8	7.0	30.8	7.9
07/27	27.2	6.1	7.1	35.5	8.4
07/28	27.1	6.7	3.6	35.5	7.2
07/29	27.3	6.8	5.2	37.8	8.9
07/30	26.9	6.7	4.7	36.5	7.3
07/31	27.0	6.8	5.2	38.0	--
平均	27.9	6.8	5.2	34.0	7.7