

## 99 年 11 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
11/01	25.5	6.9	5.5	32.3	7.8
11//02	25.9	6.9	5.2	31.3	6.6
11/03	26.0	7.0	5.3	30.9	7.9
11/04	26.1	6.9	4.7	33.6	8.5
11/05	25.9	6.9	5.2	35.3	8.9
11//06	26.3	6.9	5.3	36.3	--
11/07	25.7	6.8	4.7	38.7	--
11/08	26.1	6.9	5.3	37.9	8.8
11/09	26.3	6.9	4.9	35.5	8.0
11/10	26.1	7.0	5.7	31.3	6.8
11/11	26.5	7.0	4.5	40.4	9.4
11/12	26.4	7.0	5.1	31.7	7.5
11/13	26.0	6.9	5.3	43.9	--
11/14	26.4	7.0	5.7	29.3	--
11/15	26.1	7.0	5.1	43.1	9.8
11/16	26.4	7.0	5.5	26.7	7.2
11/17	26.0	7.1	5.1	38.6	9.4
11/18	26.2	7.2	5.7	32.0	8.1
11/19	26.2	7.0	5.1	31.5	7.9
11/20	24.9	7.0	4.9	37.4	--
11/21	25.0	6.9	4.5	39.0	--
11/22	25.7	7.0	4.8	32.5	9.3
11/23	26.2	7.0	5.1	30.2	7.4
11/24	26.1	7.0	4.5	35.3	8.0
11/25	26.1	7.0	4.8	40.8	8.9
11/26	26.1	6.9	5.3	32.7	7.4
11/27	25.0	7.0	5.9	30.5	--
11/28	25.0	7.0	5.3	36.1	--
11/29	25.7	7.0	4.5	29.7	9.4
11/30	25.5	7.0	5.0	32.1	8.0
平均	25.9	7.0	5.1	34.6	8.2