

100 年 01 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
01/01	25.1	6.9	7.3	25.9	--
01/02	26.1	6.8	5.1	26.7	--
01/03	23.4	6.8	4.9	30.8	10.5
01/04	24.2	6.9	6.9	37.1	12.7
01/05	24.4	6.8	4.1	36.1	10.2
01/06	24.6	7.0	4.8	32.0	8.5
01/07	24.4	7.0	4.7	40.6	12.1
01/08	24.7	6.9	4.2	28.3	--
01/09	25.7	7.0	4.1	26.7	--
01/10	23.6	6.9	4.9	28.3	9.2
01/11	24.0	6.9	4.5	29.8	10.4
01/12	23.6	6.9	5.8	34.1	9.8
01/13	23.8	6.9	4.7	34.5	8.7
01/14	24.4	6.9	5.5	34.4	10.5
01/15	20.9	7.1	5.0	34.8	--
01/16	20.9	6.9	5.5	34.8	--
01/17	23.1	6.9	5.9	34.0	10.2
01/18	23.7	6.9	6.4	31.3	8.5
01/19	24.4	6.8	6.2	34.4	7.4
01/20	24.6	6.8	6.2	32.8	9.4
01/21	24.2	6.9	5.3	38.8	11.3
01/22	24.6	6.9	8.7	39.2	--
01/23	24.9	6.8	8.4	29.4	--
01/24	22.5	6.8	8.1	40.0	12.5
01/25	23.9	6.9	6.8	32.4	9.2
01/26	24.0	6.9	6.8	37.1	11.1
01/27	23.7	6.8	6.0	31.3	8.2
01/28	24.4	6.9	6.5	38.4	10.9
01/29	24.2	6.9	7.4	39.0	--
01/30	25.1	6.9	9.1	35.9	--
01/31	21.8	6.9	6.1	34.3	10.9
平均	24.0	6.9	6.0	33.7	10.1