

## 100年05月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
05/01	23.7	6.9	7.0	34.5	--
05/02	26.2	6.5	5.1	28.5	11.8
05/03	26.2	6.8	5.0	33.6	12.2
05/04	25.8	6.7	4.1	39.6	12.0
05/05	26.4	6.5	5.3	32.4	10.7
05/06	26.3	6.8	6.9	33.9	11.2
05/07	25.3	7.0	6.2	30.5	--
05/08	25.0	6.8	5.0	30.5	--
05/09	26.2	6.8	5.5	34.1	10.4
05/10	26.0	6.8	5.0	45.2	11.6
05/11	26.7	6.8	5.3	29.1	9.8
05/12	26.9	6.8	4.6	34.7	10.2
05/13	27.2	6.7	3.8	30.2	9.7
05/14	26.6	6.8	5.6	36.4	--
05/15	26.4	6.5	4.2	32.4	--
05/16	26.7	6.7	4.9	30.4	11.7
05/17	26.2	6.9	4.4	29.2	10.8
05/18	26.3	6.7	9.0	36.4	11.6
05/19	27.4	6.9	7.1	36.3	9.6
05/20	28.1	6.8	8.2	42.6	10.3
05/21	26.6	6.9	4.4	32.5	--
05/22	25.6	7.0	5.3	30.9	--
05/23	27.9	6.8	6.2	33.7	11.4
05/24	28.3	6.8	5.9	30.6	12.1
05/25	28.2	6.8	5.0	33.9	8.9
05/26	28.3	6.8	4.9	34.1	10.7
05/27	28.9	6.8	5.2	26.7	12.6
05/28	26.4	6.8	9.8	28.4	--
05/29	26.8	6.9	7.1	38.8	--
05/30	28.2	6.8	6.9	36.0	10.3
05/31	28.7	6.8	6.9	37.2	11.5
平均值	26.8	6.8	5.8	33.7	11.0