

## 101 年 07 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
07/01	28.6	7.0	4.4	27.5	--
07/02	29.1	7.0	8.2	26.7	9.8
07/03	29.6	6.9	9.3	26.6	8.7
07/04	29.3	7.0	8.9	34.5	10.2
07/05	29.4	7.0	4.5	28.0	9.5
07/06	29.5	7.0	4.8	33.5	9.6
07/07	29.7	7.0	6.1	31.3	--
07/08	29.8	7.0	5.0	27.3	--
07/09	29.3	7.0	3.8	35.3	9.6
07/10	29.5	6.9	3.9	36.3	10.1
07/11	29.0	6.8	6.6	27.5	8.5
07/12	28.9	6.9	2.8	26.8	12.6
07/13	29.7	6.9	4.7	31.5	11.4
07/14	29.2	7.0	5.5	30.5	--
07/15	28.7	6.9	4.0	26.5	--
07/16	29.2	6.9	2.7	20.1	9.0
07/17	29.0	6.8	7.9	26.5	8.0
07/18	28.9	6.9	4.6	29.6	8.4
07/19	29.2	6.9	4.8	25.3	9.6
07/20	29.0	6.9	5.8	31.3	10.5
07/21	26.3	6.9	7.7	33.6	--
07/22	27.4	6.9	4.6	28.8	--
07/23	28.6	6.8	4.9	25.2	11.2
07/24	29.1	6.8	6.4	32.1	12.0
07/25	27.8	6.9	5.9	26.8	8.5
07/26	26.8	7.0	3.5	28.0	7.1
07/27	27.5	6.9	4.5	26.3	9.2
07/28	27.8	6.9	5.6	30.4	--
07/29	28.3	7.0	4.7	24.8	--
07/30	27.2	7.0	3.7	28.4	8.8
07/31	27.6	6.9	4.6	24.1	10.1
平均值	28.7	6.9	5.3	28.7	9.7