

100 年 09 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
09/01	29.0	7.0	5.4	35.1	12.0
09/02	29.2	6.9	5.8	43.6	10.1
09//03	27.9	7.0	3.7	28.5	--
09/04	28.1	7.1	5.2	26.9	--
09/05	28.8	6.9	5.0	27.3	--
09/06	29.4	7.0	5.6	30.3	9.9
09/07	29.3	6.9	5.5	32.3	8.2
09/08	29.4	6.9	6.0	29.9	7.4
09/09	29.7	6.8	3.9	30.6	9.1
09/10	28.1	6.9	4.1	25.4	--
09/11	29.3	6.8	6.6	31.7	--
09/12	28.9	6.9	4.3	32.5	--
09/13	29.0	7.0	4.4	31.3	8.0
09/14	29.6	7.0	4.2	25.0	7.3
09/15	29.5	7.0	3.0	26.0	7.8
09/16	29.6	6.9	3.2	29.1	8.7
09/17	29.6	7.0	6.8	30.6	--
09/18	29.7	7.0	11.3	28.2	--
09/19	28.8	6.9	2.7	22.6	--
09/20	29.3	7.0	4.2	24.5	9.2
09/21	28.8	7.0	5.1	28.0	7.7
09/22	28.8	7.0	4.4	31.3	8.0
09/23	28.9	7.0	6.0	27.2	7.1
09/24	28.7	6.9	4.9	32.7	--
09/25	28.9	6.9	5.4	30.3	--
09/26	29.0	6.8	5.1	40.2	--
09/27	29.3	6.9	5.3	28.4	6.4
09/28	29.4	6.9	6.0	31.0	10.4
09/29	28.5	7.0	4.2	39.4	6.7
09/30	29.5	6.9	4.4	25.2	7.3
平均值	29.1	6.9	5.1	30.2	8.4