

100 年 10 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp ( °C )	PH	SS ( mg/L )	COD ( mg/L )	BOD <sub>5</sub> ( mg/L )
10/01	28.0	6.9	4.6	28.4	--
10/02	27.8	7.0	4.2	28.8	--
10/03	28.4	7.0	4.6	27.2	--
10/04	28.6	7.0	4.5	28.5	6.2
10/05	28.7	7.0	5.6	27.1	6.1
10/06	28.9	6.9	5.0	26.3	10.3
10/07	28.9	7.0	4.9	27.4	8.2
10/08	28.5	7.0	4.7	31.6	--
10/09	27.6	6.9	4.8	29.2	--
10/10	28.3	6.9	5.0	29.2	--
10/11	29.0	6.9	4.2	33.2	5.2
10/12	29.2	6.9	6.6	23.7	5.7
10/13	28.9	6.9	6.0	25.4	8.9
10/14	28.7	6.9	4.9	24.4	9.5
10/15	28.5	7.0	7.9	35.5	--
10/16	28.7	7.0	5.4	28.3	--
10/17	27.5	7.0	5.9	26.3	--
10/18	28.5	6.9	7.8	25.6	5.2
10/19	28.2	6.9	7.0	25.1	8.4
10/20	28.1	6.9	7.2	28.6	8.2
10/21	28.5	6.9	8.4	25.6	8.4
10/22	28.4	6.9	5.6	24.9	--
10/23	28.9	7.0	5.1	24.9	--
10/24	28.4	6.9	6.3	26.1	--
10/25	28.7	6.9	6.7	23.5	4.4
10/26	28.3	6.9	5.0	32.7	7.7
10/27	28.1	6.9	3.7	33.7	5.7
10/28	28.2	6.9	4.1	33.1	11.3
10/29	27.6	6.9	4.5	36.4	--
10/30	27.6	7.0	5.0	35.6	--
10/31	27.9	6.8	3.5	35.2	--
平均值	28.4	6.9	5.4	28.8	7.5