

100 年 11 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/01	28.2	6.9	4.6	29.3	7.5
11/02	28.1	7.0	5.2	29.7	8.4
11//03	28.5	6.9	6.5	38.6	9.1
11/04	28.4	6.9	6.8	34.9	9.5
11/05	28.4	7.0	6.6	24.3	--
11/06	28.1	6.9	6.4	27.5	--
11/07	28.6	6.9	6.6	27.5	--
11/08	28.2	6.9	4.8	24.8	11.5
11/09	28.1	7.0	7.8	36.1	8.9
11/10	27.7	7.0	7.4	33.7	9.7
11/11	27.1	6.9	7.6	27.6	7.4
11/12	26.9	6.9	5.2	30.3	--
11/13	27.6	6.8	5.3	27.1	--
11/14	27.3	6.9	5.5	29.1	--
11/15	27.4	6.9	5.7	25.1	12.0
11/16	27.7	6.9	8.3	32.8	9.7
11/17	28.1	6.9	6.5	35.2	9.8
11/18	27.8	7.0	4.6	28.0	9.6
11/19	26.8	6.8	4.9	30.7	--
11/20	26.1	7.0	5.0	31.5	--
11//21	27.3	6.9	5.5	33.1	--
11/22	27.8	6.9	6.1	29.0	8.5
11/23	27.7	6.9	6.0	30.5	8.7
11/24	27.2	6.9	5.0	29.7	5.8
11/25	27.3	6.9	6.9	29.6	9.6
11/26	27.3	6.9	6.5	31.6	--
11/27	27.3	6.9	5.4	30.8	--
11/28	26.7	6.9	6.0	30.0	--
11/29	27.5	6.9	6.5	28.5	8.4
11/30	27.6	6.9	8.8	29.6	8.7
平均值	27.6	6.9	6.1	30.2	9.0