

100 年 12 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
12/01	27.4	6.9	6.9	30.1	9.5
12/02	26.8	6.9	8.9	28.9	8.9
12/03	26.8	7.0	7.1	32.4	--
12/04	26.1	6.9	6.1	30.8	--
12/05	26.5	6.8	4.0	31.2	--
12/06	26.5	6.9	6.1	27.9	8.8
12/07	27.0	6.9	8.6	25.1	10.8
12/08	27.0	6.8	7.2	30.7	10.3
12/09	26.3	6.9	6.9	32.1	10.3
12/10	25.2	6.9	5.6	26.4	--
12/11	25.7	6.9	6.0	32.4	--
12/12	26.0	6.8	7.0	28.4	--
12/13	26.4	6.8	7.5	30.0	8.8
12/14	26.4	6.8	7.8	36.7	9.1
12/15	26.2	6.9	6.2	26.3	7.9
12/16	26.1	6.9	6.5	25.7	9.7
12/17	26.0	6.9	5.8	25.2	--
12/18	26.2	6.9	5.4	32.4	--
12/19	25.7	6.8	4.0	28.8	9.1
12/20	25.4	6.9	5.1	28.9	10.0
12/21	25.8	6.9	7.9	30.5	7.3
12/22	26.1	6.9	5.1	33.7	11.1
12/23	25.7	6.9	6.4	33.7	13.0
12/24	24.4	6.9	6.6	28.9	--
12/25	24.9	7.0	6.4	32.9	--
12/26	24.7	6.9	6.5	25.7	8.5
12/27	25.6	6.8	7.4	26.6	8.9
12/28	25.1	6.9	7.0	33.3	8.8
12/29	25.4	7.0	7.4	27.3	11.7
12/30	25.3	6.9	6.2	32.4	12.9
12/31	23.6	6.9	7.0	35.6	--
平均值	25.9	6.9	6.5	30.0	9.8