

## 101 年 02 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
02/01	25.2	7.0	4.8	31.7	10.9
02/02	25.2	6.9	8.2	27.6	8.8
02/03	24.5	7.0	6.5	27.2	7.8
02/04	24.8	7.0	6.8	32.1	--
02/05	25.7	6.9	7.5	31.3	--
02/06	26.1	6.9	7.9	29.3	7.8
02/07	26.3	7.0	8.9	43.4	15.8
02/08	24.8	7.1	9.0	28.1	7.1
02/09	23.5	7.0	9.8	21.3	6.3
02/10	24.4	7.0	8.9	29.1	8.6
02/11	24.4	6.9	7.2	32.3	--
02/12	23.9	6.9	6.9	25.1	--
02/13	25.0	6.9	9.0	26.7	6.1
02/14	25.7	7.0	14.1	33.2	5.6
02/15	25.2	7.0	10.4	29.8	9.5
02/16	25.3	7.0	11.2	28.9	8.7
02/17	25.1	7.0	7.8	34.0	13.1
02/18	24.7	6.9	7.5	30.8	--
02/19	24.5	6.9	4.8	30.8	--
02/20	24.8	6.9	4.2	23.6	10.1
02/21	25.2	6.9	9.6	25.9	13.6
02/22	25.8	7.0	7.9	32.0	8.5
02/23	26.7	6.9	6.2	24.0	8.5
02/24	24.5	7.0	4.9	28.4	9.6
02/25	24.9	7.0	6.2	22.3	--
02/26	24.8	7.0	5.8	34.7	--
02/27	25.4	7.0	7.8	25.9	--
02/28	24.5	7.0	6.9	30.7	--
02//29	25.0	7.0	7.0	27.5	9.3
平均值	25.0	7.0	7.7	29.2	9.2