

## 101 年 04 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
04/01	26.8	7.0	5.8	26.5	--
04/02	27.0	7.0	5.6	24.1	8.6
04/03	27.9	7.0	4.0	22.0	7.5
04/04	25.6	7.0	4.6	31.6	
04/05	27.7	7.0	4.3	29.2	10.1
04/06	27.4	7.0	4.4	30.3	12.4
04/07	25.7	7.0	5.9	28.9	--
04/08	26.0	6.8	7.7	27.3	--
04/09	27.1	6.9	6.4	21.7	10.0
04/10	27.6	7.0	6.3	26.8	6.2
04/11	27.9	7.0	8.6	29.3	8.6
04/12	28.0	7.0	9.6	38.0	11.5
04/13	27.9	6.9	5.3	29.6	8.3
04/14	28.2	7.0	6.1	42.6	--
04/15	28.1	6.9	10.1	29.1	--
04/16	27.7	6.9	4.0	29.1	7.5
04/17	26.9	6.8	4.0	23.2	9.0
04/18	26.8	6.8	4.1	25.2	8.2
04/19	26.8	6.8	6.1	32.5	6.4
04/20	27.3	7.0	5.1	23.5	7.9
04/21	25.9	7.0	8.9	26.3	--
04/22	25.9	6.9	10.1	27.9	--
04/23	27.1	7.0	4.7	33.5	9.0
04/24	27.4	7.0	5.3	36.5	8.6
04/25	27.5	7.0	4.4	24.4	11.0
04/26	27.1	6.9	5.0	27.2	13.0
04/27	27.4	6.9	4.6	32.7	9.8
04/28	27.8	7.0	7.8	28.3	--
04/29	28.0	7.0	4.7	29.1	--
04/30	26.9	7.0	5.6	25.9	9.0
平均值	27.2	7.0	6.0	28.7	9.1