

101 年 08 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
08/01	27.6	6.9	3.2	29.5	9.5
08/02	26.2	7.0	7.7	29.1	6.3
08/03	27.2	6.9	3.2	30.9	8.4
08/04	27.6	6.9	5.7	27.9	--
08/05	27.5	7.0	6.6	26.3	--
08/06	27.2	7.0	4.4	26.3	8.8
08/07	27.5	6.9	6.0	24.3	9.5
08/08	27.5	6.9	5.8	29.8	8.9
08/09	27.2	7.0	3.2	23.0	6.9
08/10	27.5	7.0	3.1	30.6	10.9
08/11	27.4	6.9	3.0	29.6	--
08/12	27.6	6.9	6.4	28.8	--
08/13	27.6	7.0	3.6	26.8	7.9
08/14	27.5	6.9	3.3	26.4	8.4
08/15	27.6	7.0	3.8	28.0	8.3
08/16	28.0	6.9	3.9	27.6	8.8
08/17	28.0	6.9	3.2	29.5	10.0
08/18	27.4	7.0	5.9	25.4	--
08/19	28.2	6.8	4.0	24.6	--
08/20	27.3	6.9	3.5	23.0	6.9
08/21	27.5	6.9	4.3	28.4	8.5
08/22	27.9	7.0	4.5	34.1	10.2
08/23	26.8	7.0	4.0	31.5	9.5
08/24	27.5	6.9	5.8	26.8	8.0
08/25	27.4	6.9	5.4	37.1	--
08/26	27.8	7.0	7.1	33.1	--
08/27	27.4	6.9	3.9	29.1	8.7
08/28	27.5	7.0	4.5	29.4	10.2
08//29	27.5	7.0	6.5	30.1	10.9
08/30	27.5	6.9	4.2	28.0	13.8
08/31	27.5	6.9	5.3	27.5	10.0
平均值	27.5	6.9	4.7	28.5	9.1