

101 年 09 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
09/01	27.4	6.9	5.5	26.3	--
09/02	27.5	7.0	7.3	32.7	--
09/03	27.1	7.0	3.6	21.5	10.5
09/04	27.6	7.3	4.6	27.1	11.8
09/05	27.7	6.9	7.3	27.4	12.3
09/06	27.8	7.0	3.9	30.8	11.9
09/07	27.5	7.0	6.6	32.3	8.9
09/08	29.8	7.0	3.4	30.4	--
09/09	30.1	7.0	6.8	28.0	--
09/10	27.8	7.0	7.1	30.4	10.8
09/11	27.7	7.0	6.5	34.9	10.4
09/12	28.2	7.2	7.5	31.9	9.5
09/13	27.8	6.9	8.5	33.9	10.2
09/14	29.4	6.9	7.6	30.9	9.3
09/15	27.3	6.9	6.7	27.2	--
09/16	26.4	7.0	5.9	26.4	--
09/17	28.3	6.9	6.2	29.6	8.9
09/18	28.3	7.0	5.4	29.9	9.1
09/19	28.5	7.0	7.3	31.7	8.4
09/20	27.2	7.1	5.2	30.0	8.5
09/21	28.7	7.0	5.3	30.5	9.2
09/22	28.2	7.0	7.1	30.7	--
09/23	28.0	6.9	7.8	29.9	--
09/24	28.2	7.0	5.4	25.5	7.6
09/25	28.0	7.0	4.8	31.6	9.5
09/26	28.2	7.0	4.6	28.0	8.4
09/27	27.6	6.9	4.4	27.1	8.1
09/28	28.2	7.0	6.2	27.9	8.4
09//29	26.8	7.0	6.4	28.2	--
09/30	27.2	7.0	8.5	26.6	--
平均值	28.0	7.0	6.1	29.3	9.6