

101 年 12 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
12/01	25.8	7.0	8.7	30.8	--
12/02	25.4	6.9	9.9	38.8	--
12/03	24.8	7.1	10.7	27.2	7.6
12/04	25.4	6.9	8.9	27.5	8.5
12/05	25.8	7.0	9.7	25.1	10.1
12/06	25.1	7.0	6.7	30.7	10.5
12/07	25.3	6.9	6.3	26.6	11.9
12/08	23.1	7.0	7.8	27.1	--
12/09	22.9	7.0	8.0	30.3	--
12/10	24.1	6.7	9.7	26.7	9.3
12/11	25.1	6.9	7.4	31.9	11.2
12/12	24.8	7.1	5.0	25.8	8.2
12/13	25.0	7.0	5.7	30.2	9.1
12/14	24.9	6.9	5.1	29.8	8.9
12/15	27.2	7.0	6.8	23.1	--
12/16	27.1	6.9	7.0	38.2	--
12/17	25.2	6.8	7.8	28.7	7.7
12/18	25.6	7.0	8.2	38.6	11.5
12/19	24.8	7.0	9.0	37.3	10.5
12/20	24.7	6.9	8.4	29	9.3
12/21	25.1	6.9	8.4	27.5	7.8
12/22	25.2	7.0	11.9	39.3	--
12/23	22.1	7.0	8.5	36.3	--
12/24	23.0	6.9	7.4	27.5	8.6
12/25	25.0	6.9	10.5	31.1	7.5
12/26	25.5	6.9	9.0	29.8	8.1
12/27	25.2	7.0	10.2	36.1	7.2
12/28	25.0	7.0	6.0	28.6	7.0
12/29	25.5	7.0	8.9	40.2	--
12/30	22.2	6.9	9.6	29.9	--
12/31	23.9	6.9	6.0	27.1	--
平均值	24.8	6.9	8.2	30.9	9.0