

102 年 02 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
02/01	24.5	6.9	8.0	33.3	9.3
02/02	24.5	7.0	5.9	29.6	--
02/03	24.9	7.0	6.8	31.6	--
02/04	24.8	6.9	10.1	34.0	9.5
02/05	25.1	7.1	9.1	32.4	7.2
02/06	25.2	7.0	7.5	34.4	10.3
02/07	25.0	7.2	9.0	21.6	8.6
02/08	24.2	6.9	6.7	25.9	9.0
02/09	25.0	6.7	7.0	20.6	--
02/10	24.6	7.0	7.3	22.2	--
02/11	24.9	7.0	6.0	21.4	--
02/12	25.3	6.9	6.0	20.6	--
02/13	24.2	6.9	7.3	21.8	--
02/14	25.0	6.9	6.4	23.4	--
02/15	25.3	7.1	8.2	25.8	--
02/16	25.5	7.0	8.1	26.8	--
02/17	25.5	7.0	9.3	26.8	--
02/18	24.8	7.0	6.0	24.4	7.6
02/19	25.5	7.0	10.9	30.8	8.8
02/20	24.5	7.1	10.0	26.4	10.3
02/21	24.4	7.1	9.2	27.6	8.9
0222	24.1	7.0	11.3	27.5	6.8
02/23	24.2	7.0	10.8	26.5	--
02/24	24.4	7.0	12.0	28.1	--
02/25	24.4	7.0	10.1	24.9	8.4
02/26	25.3	7.0	10.7	29.7	11.8
02/27	25.3	7.0	12.0	32.5	11.8
02/28	25.2	6.9	9.4	26.7	--
平均值	24.8	7.0	8.6	27.0	9.2