

102 年 04 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
04/01	26.1	7.0	7.7	24.0	--
04/02	26.5	7.3	11.6	32.0	10.7
04/03	26.1	7.0	7.6	26.9	7.6
04/04	24.2	7.0	8.0	27.3	--
04/05	23.2	6.9	8.3	31.3	--
04/06	24.1	6.9	8.2	27.3	--
04/07	25.1	7.0	7.0	27.3	--
04/08	25.5	7.1	10.1	21.7	--
04/09	25.6	7.1	6.6	26.1	7.2
04/10	25.8	7.0	5.4	35.0	9.2
04/11	25.8	7.0	6.7	37.6	8.9
04/12	25.3	7.1	8.0	33.1	8.8
04/13	24.7	7.0	7.9	25.1	--
04/14	24.0	7.1	9.6	28.6	--
04/15	25.8	7.1	7.6	29.8	--
04/16	26.2	7.0	5.9	27.7	9.1
04/17	25.9	7.1	9.1	23.7	7.9
04/18	27.0	6.8	9.9	28.5	7.4
04/19	27.2	7.1	8.5	32.5	8.8
04/20	25.8	6.9	10.1	28.9	--
04/21	26.1	6.9	7.6	26.9	--
04/22	26.5	7.1	7.2	28.5	--
04/23	26.5	7.1	6.0	28.6	9.5
04/24	26.4	7.1	7.4	33.6	9.8
04/25	26.8	7.2	5.4	25.5	7.4
04/26	26.4	7.1	8.2	29.3	9.0
04/27	25.3	7.0	6.4	30.9	--
04/28	25.9	7.0	8.8	28.7	--
04/29	27.1	7.2	9.6	33.9	--
04/30	27.0	7.2	12.8	33.8	8.8
平均值	25.8	7.0	8.1	29.1	8.7