

## 102 年 05 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
05/01	26.2	7.2	6.0	26.8	8.0
05/02	26.3	7.1	7.3	31.3	6.3
05/03	26.3	7.2	7.0	31.3	7.4
05/04	26.2	7.0	7.2	26.8	--
05/05	26.4	7.1	7.0	27.1	--
05/06	26.5	7.1	7.8	25.3	8.0
05/07	26.5	7.1	8.0	26.7	--
05/08	26.2	7.2	8.0	24.8	8.5
05/09	26.3	7.1	7.1	22.8	8.1
05/10	26.8	7.2	6.0	26.8	8.0
05/11	27.0	7.0	7.1	32.5	--
05/12	27.5	6.9	7.5	30.0	--
05/13	27.9	7.0	7.0	28.9	7.9
05/14	27.7	7.2	7.7	26.5	--
05/15	29.3	7.2	8.2	29.2	7.2
05/16	27.9	6.9	7.9	30.6	6.8
05/17	27.8	7.0	8.0	27.6	7.4
05/18	27.8	6.9	7.8	30.2	--
05/19	27.9	7.0	7.6	28.4	--
05/20	28.0	7.0	8.4	31.7	7.8
05/21	27.8	7.0	7.8	26.9	--
05/22	28.2	7.1	7.4	35.3	8.1
05/23	27.9	6.9	8.6	32.5	7.1
05/24	28.0	7.0	6.2	26.6	8.5
05/25	27.9	7.1	6.8	28.2	--
05/26	28.2	7.0	7.8	27.7	--
05/27	28.4	7.2	8.0	33.6	7.8
05/28	28.2	7.1	8.0	29.8	--
05/29	28.6	7.2	7.6	24.9	7.6
05/30	28.9	7.1	6.8	31.7	8.5
05/31	28.6	7.1	6.5	29.2	8.7
平均值	27.5	7.1	7.4	28.8	7.8