

102 年 08 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
08/01	28.3	6.7	6.0	25.0	7.3
08/02	28.7	7.0	7.2	28.2	10.9
08/03	28.0	6.8	7.5	26.5	--
08/04	28.3	6.8	7.4	30.4	--
08/05	28.8	6.9	6.2	26.9	8.5
08/06	28.9	6.9	6.2	30.7	8.2
08/07	28.8	6.8	8.2	30.3	8.6
08/08	28.9	6.8	7.3	28.3	7.8
08/09	29.1	6.7	8.7	30.7	9.2
08/10	28.1	6.8	10.0	34.5	--
08/11	28.3	6.9	9.1	30.3	--
08/12	29.0	6.8	7.4	28.6	7.3
08/13	28.8	6.9	8.2	30.8	8.2
08/14	28.8	6.7	9.2	25.6	8.8
08/15	29.0	6.8	7.6	30.3	6.7
08/16	28.7	6.7	5.4	29.1	6.5
08/17	28.2	6.7	7.0	27.1	--
08/18	28.2	6.9	8.1	28.3	--
08/19	29.4	6.8	6.6	30.9	7.9
08/20	28.6	6.8	6.3	25.4	7.5
08/21	28.6	6.7	7.4	28.2	8.6
08/22	27.0	6.7	10.7	30.8	7.1
08/23	27.6	6.6	8.6	23.2	8.9
08/24	28.1	6.9	5.8	26.8	--
08/25	28.3	6.9	4.4	27.3	--
08/26	28.6	6.9	7.4	25.1	6.8
08/27	28.6	6.8	5.1	25.1	7.4
08/28	28.7	7.0	8.0	23.4	7.3
08/29	27.6	6.9	10.9	24.8	8.4
08/30	27.0	7.0	12.0	25.2	8.8
08/31	27.0	6.8	10.4	17.9	--
平均值	28.4	6.8	7.8	27.6	8.0